



AOM CERTIFICATE OF PERFORMANCE – HC SERIES HOODS

AOM HC Series Hoods are certified to meet the requirements of a Type 7 proprietary hood as per AS1668.2-2012 Section 3.6 (see attachment).

The basis for *these designs is to lower energy costs by reducing exhaust air requirements.*

AOM HC Series Hood airflows are therefore calculated using the German Guideline VDI 2052 *Ventilation equipment for kitchens.*

AOM has designed the hoods so as to equip them with high efficiency filtration equipment when this is a requirement. The filtration equipment (FILTRAIR) is composed of three filtration steps as follows:

1. Stainless steel honey comb filters which filters the large grease particles.

These filters have been tested and certified to meet AS 1530 Methods for fire test on building materials, components and structures, Part 1 1994: Combustibility test for materials (see attached).

2. Electrostatic filtration which filters the smaller grease and smoke particles.

Electrostatic filters are a proven and widely used filtration method for kitchen exhaust. ASHRAE Systems & Equipment 1996 testing results concluded that "Electronic air cleaners can be highly efficient filters using electrostatic precipitation to remove and collect particulate contaminants such as dusts, smoke, and pollen. The designation electronic air cleaner denotes a precipitator for HVAC air filtration. This type of air cleaner can remove and collect contaminants with an average efficiencies up to 98%, when tested in accordance with ASHRAE Standard 52.1.

3. Ozone generation for subsequent odour control using the AOM ozone generator which is situated outside of the airflow and injects ozone into the exhaust air system.

Independent odour emissions testing of AOM Electrostatic filtration and Ozone injection equipment installed at a McDonald's restaurant by a NATA-Accredited TOU Sydney Laboratory to AS/NZS4323.3:2001 Standard found that the AOM system had:

- A lower limit odour destruction efficiency of 69%
- An upper limit odour destruction efficiency of 86.6%
- A mean odour destruction efficiency of 79.6%

The AOM FILTRAIR system is currently the only in hood system on the market that has been tested and certified by a recognised Australian agency to filter commercial kitchen exhaust. The University of Sydney carried out efficiency testing on a Type 4 cooking exhaust as per AS1668.2-2012: *High grease, medium heat producing equipment such as countertop barbecues and gas fired deep fat fryers.*

AOM AUSTRALIA

21/54 BEACH ST KOGARAH NSW 2217 Tel 1300 903 788 Fax 1300 904 088

www.aomaus.com.au Email info@aomaus.com.au



Results concluded that *AOM FILTRAIR Technology which includes honeycomb filters and electrostatic precipitators (single pass system) can effectively remove more than 98% of smoke and/or grease particles from commercial kitchen exhaust systems (see attachment).*

The tests were conducted on a single pass electrostatic filtration setup and concluded that *after the treatment with AOM Australia's combined Honeycomb and electrostatic precipitator filter, almost all smoke and grease particles (>2 micron) have been eliminated from the exhaust.*

Tests were also carried out on a double pass setup (two electrostatic filters in series) and results were situated out of the testing protocol range (range was between 0.5-900 micron).

The laboratory test results have been confirmed by in-situ tests. Independent test were carried out during high volume cooking sessions (lunch) at a heavy type 4 cooking tenancy (gas chargrilling of steaks, meat, burgers, bacon). Particle sampling was undertaken before and after an AOM EAN Series electrostatic precipitators with a face velocity of 2.5 m/s and concluded:

These results indicate that the kitchen exhaust treatment systems tested are in our opinion capable of achieving an equivalent filtration efficiency of at least 98%. This is assuming regular maintenance is carried out to ensure the systems are operating correctly.

These independent testing results place AOM Australia at the forefront of kitchen exhaust filtration in Australia and New Zealand. No other kitchen exhaust hood on the market is able to independently certify a filtration efficiency to kitchen exhaust airflows. With the filtration equipment situated within the exhaust canopy, kitchen exhaust emissions are filtered at the source of the contamination.

It can therefore be stated that when an AOM HC Series hood is installed and when the equipment is serviced and maintained following AOM recommendations, the kitchen exhaust hoods meet the requirements of a kitchen exhaust engineered solution as per AS1668.2-2012 and may allow, on a case per case basis, to achieve horizontal discharge of kitchen exhaust.

A handwritten signature in black ink, appearing to read 'Sven Bolomey', written over a horizontal line.

Air and Odour Management Australia
Sven Bolomey, Managing Director

Note: Defined testing ranges follow typical particle sizes for the exhaust emissions from kitchen exhausts as defined in AIRAH Technical Bulletin 2016: Fire Safety Kitchen Hood Exhaust Systems:

- Smoke: up to 0.5 micron
- Grease steam: 0.5 – 6 micron
- Grease splatter: greater than 6 micron

All test report are available upon request.

AOM AUSTRALIA

21/54 BEACH ST KOGARAH NSW 2217 Tel 1300 903 788 Fax 1300 904 088

www.aomaus.com.au Email info@aomaus.com.au

Certificate of Approval

This certificate confirms that the company below complies with the following standard:

Company Name	Air & Odour Management Australia (AOM)	Client ID	101837
Company Other Name	Technics Security Australia Pty Ltd	Type of Certification	Product Certification; System 5
Certification Standard	AS 1668.2-2012 : The use of ventilation and air-conditioning in buildings - Appendix E Kitchen exhaust hoods – design, construction and installation		
Certification Review Date	29/01/2013	Certification Expiry Date	29/01/2018
Certificate Issue Date	14/10/2013	Certificate Last Update Date	8/10/2013

APPROVED COMPANY/SITE ADDRESS(ES):

22/54 Beach Street Kogarah 2217 NSW Australia

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654.



Certification Manager



Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:

Model Identification	Model Name	Brand Name	Product Description/ Attributes	Date Approved
HCES	HCES	AOM	Proprietary type7 Exhaust hood with or without supply air plenum	8/10/2013
HCOS	HCOS	AOM	Proprietary type7 exhaust hood with ozone generator and with or without supply air plenum	8/10/2013
HCFS	HCFS	AOM	Proprietary type7 exhaust hood with electrostatic filters and with or without supply air plenum	8/10/2013
HCFOS	HCFOS	AOM	Proprietary type7 exhaust hood with electrostatic filters, ozone generators and with or without supply air plenum	8/10/2013
HCFDS	HCFDS	AOM	Proprietary type7 exhaust hood with electrostatic filters (double pass) with or without air supply plenum	8/10/2013
HCFIS	HCFIS	AOM	Proprietary type7 island exhaust hood with electrostatic filters and with or without air supply plenum	8/10/2013
HCD	HCD	AOM	Proprietary type7 dishwasher hood	8/10/2013

Comments:

HC series of proprietary type 7 exhaust hoods.

Models: HCES, HCOS, HCFS, HCFOS, HFDS, HCFIS, HCD incorporating filters AOM - Part number HS01, HS02, HS03 or HS04.


Conditions:

1. Each appliance design must be approved and certified by the manufacturer in accordance with the AOM procedures,
2. Each appliance must be type tested by the manufacturer in accordance with the AOM procedures,
3. Must be installed and commissioned in accordance with AOM Installation Instructions dated 01/10/2013 by AOM trained and approved agents.

End of the document



Certification Manager





Certificate of Analysis

Tested system & condition:

Efficiency Testing of AOM FILTRAIR™ Technology

1 x AOM hood type HCF-Series (single pass ESP filtration)

Airflow 1215 l/s

3 x AOM honeycomb filters type HS02 495 x 495 mm (405 l/s each) at air velocity of 2m/s.

3 x AOM ESP full cells.

Cooking process type 4 (as per AS 1668.2-2012)

Test Date: 29 May 2014

Requested by: AOM Air & Odour Management Australia

Particle size (volume average, micron):

Exhaust without treatment: 12.71

Exhaust with Honeycomb only: 7.53

Exhaust with Honeycomb & electrostatic precipitators (single pass): 0.74

Detailed size and distribution refer to Fig 1, attached on the next page.

Conclusion:

AOM FILTRAIR™ Technology which includes honeycomb filters and electrostatic precipitators (single pass system) can effectively remove more than **98% of smoke and/or grease particles from commercial kitchen exhaust systems.**

Tested by: Dr Jeffrey Shi

Signature



**AOM AUSTRALIA REFERENCE LIST – Selection 2013/2014/2015
(Projects over chargrills or solid fuel marked in grey)**

Draft and uncompleted on 02/06/2016

State	Year	Client	Technical characteristics
NSW	2016	The Chook Shack Shop 2B, 20-30 Blamey Street, Reversby NSW 2212	EAN 400 AOM Service Contract
NSW	2016	Grill'd MacArthur 200 Gilchrist Dr Campbelltown NSW 2560	1 x HCE Series Hood 4650x1350x800mm 1 x HCD Series Hood 1100x1200x800mm
NSW	2016	Grill'd Tuggerah Tuggerah NSW 2259	1 x HCE Series Hood 4650x1350x800mm 1 x HCD Series Hood 1100x1200x800mm
NSW	2016	McDonalds Sydney Domestic Terminal T2 Mascot NSW 2020	EAN 600
NSW	2016	Round House Restaurant Rhodes Shopping Centre Rhodes NSW 2138	EAN 400 and EAN 600
NSW	2016	Hungry Jack's Circular Quay Sydney NSW 2000	EAN 400 and EAN 300 with Ozone Generator for horizontal discharge
NSW	2016	Macelleria Bondi Pacific Bondi NSW 2026	Double Pass EAN 400 with Ozone Generator for horizontal discharge
NSW	2015	Ribs & Burgers The Rocks George street Sydney NSW 2000	Double Pass EAN 600 with Ozone Generator for horizontal discharge AOM Servicing contract
NSW	2015	La Boca Stamford Plaza Cnr O'Riordan & Robey Streets Near Domestic Airport Mascot, NSW 2020	1 x HCPF Series Hood 4200x3200x800mm
NSW	2015	Ribs & Burgers Zetland 6 Defries Ave Zetland NSW 2017	EAN 600 and Ozone Generator OG35

AOM AUSTRALIA

22/54 BEACH ST KOGARAH NSW 2217 Tel 1300 903 788 Fax 1300 904 088

www.aomaus.com.au

Email: info@aomaus.com.au

NSW	2015	Ribs & Burgers Rhodes Rider Blvd Rhodes NSW 2138	EAN 600
NSW	2015	Hunter and Barrel Tenancy 303 Cockle Bay Wharf Sydney NSW 2000	EAN 800 AOM Service Contract
NSW	2015	Ribs & Burgers Chatswood Victoria Ave Chatswood NSW 2067	EAN 600
NSW	2015	Grill'd The Galleries Tenancy 3, Level 1 500 George street Sydney NSW 2000	1 x HCE Series Hood 5000x1350x800mm 1 x HCE Series Hood 1350x1500x800mm 1 x HCD Series Hood 1450x1200x800mm
NSW	2015	Grill'd Kotara Shop 3010 Northcott Drive & Park Avenue Kotara NSW 2289	1 x HCE Series Hood 4650x1350x800mm 1 x HCD Series Hood 1100x1200x800mm
NSW	2015	Grand Duk Grosvenor Place Sydney 2000	1 x HCVFO Series Hood 6250x1350x550mm 1 x HCD Series Hood 1300x1200x700mm
NSW	2015	Hideaway Hotel 21 Cypress Crescent Cabarita Beach NSW 2488	1 x HCVPFO Series Hood 2600x1600x550mm 1 x HCVE Series Hood 5700x1450x550mm 1 x HCVE Series Hood 3100x1400x550mm 1 x HCVD Series Hood 1200x1200x550mm
NSW	2015	Mad Mex East Village Development Zetland NSW 2017	1 x HCFO Series Hood 3050x1350x800mm
NSW	2014	Bowen Island East Village Development Zetland NSW 2017	1 x HCFO Series Hood 3950x1350x800mm
NSW	2014	Village Crow East Village Development Zetland NSW 2017	1 x HCFO Series Hood 5000x1350x800mm 1 x HCIO Series Hood 2400 x 1700 x 800 mm 1 x HCD Series Hood 1100 x 1100 x 800 mm
NSW	2014	Dragon Dumpling East Village Development Zetland NSW 2017	1 x HCFO Series Hood 6350x1600x800mm
NSW	2014	Sushi Square East Village Development Zetland NSW 2017	1 x HCFO Series Hood 1600x1350x800mm

AOM AUSTRALIA

22/54 BEACH ST KOGARAH NSW 2217 Tel 1300 903 788 Fax 1300 904 088

www.aomaus.com.au

Email: info@aomaus.com.au

NSW	2014	Olive and Bean cafe East Village Development Zetland NSW 2017	1 x HCFO Series Hood 1950x1350x800mm
NSW	2014	Phoenix East Village East Village Development Zetland NSW 2017	1 x HCFO Series Hood 16600x1600x800mm
NSW	2014	ZooBar Oxford St Bondi Junction NSW 2026	1 x HCVFO Series Hood 2400x1350x550mm Fan and VSD
NSW	2013	Kim Lee Malaysian Restaurant Sussex Street Sydney NSW 2010	1 x HCFO Series Hood 5550x1350x800mm 1 x HCFO Series Hood 1950x1350x800mm
NSW	2013	Des Renford Leisure centre Corner Robey St & Jersey Road, Maroubra NSW 2035	1 x HCE Series Hood 2750x1350x800mm
ACT	2014	Juliana's Abode Hotel Woden ACT 2606	1 x HCFO Series Hood 3850x1350x800mm
ACT	2014	Bent Spoke Brewing company Touie Smith Sales & Services Unit5, 234 Comur Street Yass NSW 2582	1 x HCFO Series hood 6500x1350x800mm 1 x HCD Hood (Dishwasher)
ACT	2013	The Rum Bar 6/2 Trevillian Quay Kingston Foreshore Kingston ACT	1 x HCE Series Hood 3000x1200x800mm
ACT	2012	Greenway Offices Cowlshaw street Greenway ACT	1 x HCE Series Hood 8300x1350x800mm 1 x HCD (dishwasher)
VIC	2016	Dax Cafe Trinity Grammar School 40 Charles St Kew VIC 3101	Double pass EAN 400 Ozone Generator OG35
VIC	2016	Hungry Jack's 336-346 Bell Street Pascoe Vale South VIC 3044	1 x HCF(O) Series Hood 2000x1350x800mm 1 x HCVPF(O) Series Hood 1850x1400x800mm
VIC	2016	Warragul Aged Care Warragul Victoria 3820	1 x HCE Series Hood 2700x1600x700mm 1 x HCE Series Hood 3000x1350x700mm
VIC	2015	Shuji Sushi 238 Flinders Lane Melbourne VIC 3000	1 x HCFO Series Hood 2350x1500x800mm 1 x HCFO Series Hood 2850x1350x800mm
VIC	2015	Grill'd Balaclava 231-237 Carlisle St Balaclava VIC 3183	1 x HCE Series Hood 4500x1350x800mm

AOM AUSTRALIA

22/54 BEACH ST KOGARAH NSW 2217 Tel 1300 903 788 Fax 1300 904 088

www.aomaus.com.au

Email: info@aomaus.com.au

			1 x HCD Series Hood 1500x1200x800mm
VIC	2015	Rubber Duck Café VIC 3000	1 x HCF Series Hood 4230x1350x800mm
VIC	2015	Roti Road Highpoint Shopping Centre 120-200 Rosamond Rd Maribyrnong VIC 3032	1 x HCO Series Hood 2250x1250x800mm 1 x HCO Series Hood 3150x1500x800mm 1 x HCO Series Hood 6550x1500x800mm
VIC	2015	Pita Pit Tenancy 4 842 Bourke St Docklands VIC 3008	1 x HCE Series Hood 1900x1350x800mm
VIC	2015	Ozzyburgers 137 Fitzroy St St Kilda Vic 3182	1 x HCFO Series Hood 5000x1350x800mm INTAIR System (Exhaust Fan, MUA Fan, Heat Sensors)
VIC	2014	Lord of the fries Southern Cross Station Docklands VIC 3008	1 x HCVFO Series Hood 2750x1350x550mm
VIC	2014	East Restaurant 27 Little Collins St Melbourne 3000	1 x HCFO Series Hood 5350x1350x550mm
VIC	2014	Dominos Port Melbourne 3207	1 x HCIVFPO Series Hood 3150x2200x550mm Exhaust fan + VSD Make up air fan + VSD
VIC	2014	Aussie Growers 150-154 Monbulk Rd Sylvan 3795	2 x HCE Series Hood 4325x1200x400mm 2 x HCE Series Hood 2625x1200x400mm
VIC	2014	Hardware Société 120 Hardware street Melbourne 3000	1 x HCE Series Hood 2600x1200x800mm
VIC	2014	Bier Café South Wharf Melbourne	1 x HCF Series Hood 1350x1900x800mm 1 x HCF Series Hood 1950x1600x800mm 1 x HCD (Dishwasher)
VIC	2013	Gilbert's Café 39 the Esplanade Torquay 3228	1 x HCPF Series Canopy double pass Hood 2000x1500x800mm
VIC	2013	Jimmy Grant 113 St Davids street Fitzroy 3065	1 x HCE Series Hood 3400x1200x800mm 1 x HCE Series Hood 2100x1200x800mm
VIC	2013	Banoi traditional Vietnamese restaurant	1 x HCFO Series Hood 4200x1200x800mm

AOM AUSTRALIA

22/54 BEACH ST KOGARAH NSW 2217 Tel 1300 903 788 Fax 1300 904 088

www.aomaus.com.au

Email: info@aomaus.com.au

		807 Bourke Street Docklands 3000	1 x HCD Hood (Dishwasher)
VIC	2013	Hunnah Café 141 Chapel street St Kilda 3182	1 x HCFO Series Hood 1600x1950x1200mm
VIC	2013	Big Boy BBQ 2/27 Hardware Lane Melbourne Vic	1x HCFO-Series Hood 3100x1200x800mm
TAS	2014	Frank Argentinian restaurant 1 Franklin Wharf Hobart	1x HCIFO-Series Hood 3100x2600x800mm 1x HCIFO-Series Hood 1950x2600x800mm
South Australia	2015	Nandos 33 King William St Adelaide SA 5000	1 x HCPFO Series Hood 4050x1600x800mm 1 x HCFO Series Hood 1200x1250x800mm
South Australia	2014	Gouger St Adelaide SA 5000	1 x HCFO Series Hood 4950x1400x800mm
South Australia	2014	The Watson Adelaide SA 5000	1 x HCFO Series Hood 4375x1600x800mm
South Australia	2013	La Boca Argentinian restaurant 150 North Terrace, Adelaide 5000	1 x HCPF Series Hood 3400x2700x800mm
QLD	2015	Pancakes on the Rocks Shop T1.30A, T1.30B & T1.31 Soul Building 4 The Esplanade Surfers Paradise Surfers Paradise QLD 4217	1 x HCFO Series Hood 2200x1700x800mm 1 x HCTFO Series Hood 4100x2000x800mm 1 x HCFO Series Hood 4550x1350x800mm 1 x HCFO Series Hood 2150x1350x800mm
QLD	2016	Woolworths Southpoint	1 x HCFO Series wall mounted hood 1700x1400x800 mm 1 x HCFO Series wall mounted hood 1650x1900x800 mm
QLD	2015	Sea Scape Restaurant and Bar Level 1 & 2 The Esplanade Surfers Paradise QLD 4217	1 x HCVFO Series Hood 3930x1250x550mm 1 x HCIFO Series Hood 4250x3000x800mm 1 x HCD Series Hood 1400x1200x550mm 1 x HCD Series Hood 1100x1500x550mm
QLD	2015	Pure Kirra 28 Musgrave St Coolangatta QLD	1 x HCFO Series Hood 4400x1350x800mm

AOM AUSTRALIA

22/54 BEACH ST KOGARAH NSW 2217 Tel 1300 903 788 Fax 1300 904 088

www.aomaus.com.au

Email: info@aomaus.com.au

QLD	2015	Raw Energy QLD 4000	1 x HCFO Series Hood 4300x1400x800mm
QLD	2015	Grill'd Pacific Fair Shop 2743 Level 1 Pacific Fair SC Hooker Blvd Broadbeach QLD 4218	1 x HCE Series Hood 5000x1350x800mm 1 x HCE Series Hood 1600x1350x800mm 1 x HCD Series Hood 1100x1200x800mm
QLD	2015	Grill'd Albert St Albert St Brisbane QLQ	1 x HCPFO Series Hood 4550x1600x800mm 1 x HCFO Series Hood 1350x1350x800mm 1 x HCD Series Hood 1450x1200x800mm
QLD	2015	Panchvati The Plaza South Brisbane QLQ	1 x HCFO Series Hood 3900x1350x800mm
QLD	2015	Clairvaux MacKillop Canteen 24 Klumpp Road Upper Mount Gravatt QLD	1 x HCVFO Series Hood 4250x1350x550mm
QLD	2015	Guzman Y Gomez Ruthven and Alderly Streets Kearney Springs Toowoomba QLD	1 x HC(PFO)E Series Hood 4200x1600x690mm
QLD	2015	Harajuku Gyoza 52 Grey St South Brisbane QLD 4101	1 x HCFO Series Hood 2100x1600x800mm 1 x HCFO Series Hood 2100x1350x800mm
QLD	2015	Lend Lease Private BBQ area	1 x HCIFO Series Hood 2400x2400x800mm
QLD	2014	Jupiter's Hotel and Casino Level 4 restaurant Broadbeach QLD 4218	1 x HCVFO Series Hood 4900x1600x600mm 1 x HCVFPO Series Hood 2200x1600x600mm 1 x HCVFO Series Hood 4100x1600x600mm 1 x HCVFO Series Hood 1850x1200x600mm 1 x HCVFPO Series Hood 2400x1600x600mm 1 x HCVFO Series Hood 2600x1600x600mm 1 x HCVFO Series Hood 3550x1600x600mm 2 x HCVD Series Hood 1200x1200x300mm
QLD	2014	Jimmy's on the Mall Queen Street Mall Brisbane QLD 4000	1 x HCFO Series Hood 45300x1350x550mm 1 x HCFO Series Hood 4000x2700x475mm

AOM AUSTRALIA

22/54 BEACH ST KOGARAH NSW 2217 Tel 1300 903 788 Fax 1300 904 088

www.aomaus.com.au

Email: info@aomaus.com.au

QLD	2014	Maroochy River Golf Club Bli Bli QLD 4560	1 x HCFIO Series Hood 3800x1350x800mm 1 x HCFIO Series Hood 3800x1500x800mm 1 x HCD Series Hood 1200x1200x800mm
QLD	2014	Guzman Y Gomez Post Office Square Brisbane QLD 4000	1 x HCPFO Series Hood 4250x1600x800mm 1 x HCFO Series Hood 1550x1350x800mm INTAIR system including heat sensors and automatic ozone injection
QLD	2014	Guzman Y Gomez Tenancy 305 Surfers Paradise QLD 4217	1 x HC(PFO)E Series Hood 3900x1600x800mm
QLD	2014	Emporio Brisbane QLD 4000	1 x HCFO Series Hood 3750x1350x800mm
QLD	2014	St Hilda's School 52 High Street Southport QLD 4215	1 x HCFO Series Hood 5300x1350x550mm
QLD	2014	Roll'd Vietnamese take away 410 Queen St Brisbane QLD 4000	1 x HCFO Series Hood 3250x1350x800mm
QLD	2014	Roll'd Vietnamese take away 144 Edward St Brisbane QLD 4000	1 x HCFO Series Hood 3100x1350x800mm
QLD	2014	Watermark Hotel 3032 Surfers Paradise Boulevard, Surfers Paradise Queensland 4217	1 x HCPFO Series Hood 2500x1600x800mm 2 x HCFO Series Hood 4550x1350x800mm 1 x HCD Series Hood 1350x1200x800
QLD	2014	Kamikaze Harbour Rd, Hamilton QLD 4007	1 x HCIFO Series Hood 2350x1600x800mm 1 x HCFO Series Hood 2550x1200x800
QLD	2014	Red Hook Shop 3 88 Creek St Brisbane	1 x HCFO Series Hood 4100x1350x800mm
QLD	2014	Aamaya Indian Restaurant Tenancy 11 Portside wharf Hamilton	1 x HCFO Series Hood 4100x1350x800mm
QLD	2014	Windmill Brisbane Airport	1 x HCVFO Series Hood 2100x1200x550mm
QLD	2014	Navala 123 Eagle St Brisbane QLD 4000	1 x HCPFO Series Hood 5480x1600x800mm 1 x HCIFO Series Hood

AOM AUSTRALIA

22/54 BEACH ST KOGARAH NSW 2217 Tel 1300 903 788 Fax 1300 904 088

www.aomaus.com.au

Email: info@aomaus.com.au

			5150x2200x800mm
QLD	2014	Wrapped Coffee and Sandwich bar 11 Wandoo street Fortitude Valley Brisbane 4006	1 x HCPFO Series Hood 2450x1600x800mm
QLD	2013	Jackpot Dining 55 Elizabeth Street, Brisbane	1x HCFO Hood 9000x1200x800mm
QLD	2013	Enjoy Inn Shop 28/ 8 Harbour Rd, Hamilton QLD 4007	1 x HCFO Series Hood 8410x1200x800mm
WA	2016	V Burger Elizabeth Quay The Esplanade Perth WA 6000	1 x HCPFO Series wall mounted hood 4000x1600x800 mm
WA	2015	East Village Perth	1 x HCFO Series Hood 5200x1350x550mm 1 x HCFO Series Hood 2150x1600x800mm
WA	2015	Pretty Pool Cafe Port Headlands 6721 WA	1 x HCVFO Series Hood 2750x1350x550mm
WA	2015	Fushi Restaurant 20 Walters Drive Herdsman 6017 WA	1 x HCVFO Series Hood 2750x1350x550mm
WA	2014	Banksia Groves Perth WA	1 x HCFO Series Hood 4650x1600x800mm 1 x HCD Series Hood 1000x1000x800mm
Fiji	2015	Hilton Bistro Fiji	1 x HCVO Series Hood 1400x1350x550mm 1 x HCVO Series Hood 3400x1350x550mm 1 x HCVO Series Hood 2900x1600x550mm 1 x HCVO Series Hood 2000x1350x550mm 1 x HCVO Series Hood 3100x120x550mm
Fiji	2013	Amanuca Island Resort Fiji	1 x HCV Series Hood 5600x1200x800mm 1 x HCV Series Hood 1250x1200x800mm 1 x HCV Series Hood 4970x1200x800mm
Fiji	2013	Saffron Fiji Tandoori Restaurant and Mamacita Mexican Restaurant	1 x HCV Series Hood 5600x1200x800mm 1 x HCV Series Hood 1250x1200x800mm 1 x HCV Series Hood 4970x1200x800mm
NZ	2015	St James Cinema	1 x HCF Series Hood

AOM AUSTRALIA

22/54 BEACH ST KOGARAH NSW 2217 Tel 1300 903 788 Fax 1300 904 088

www.aomaus.com.au

Email: info@aomaus.com.au

		Auckland	2300x1350x700mm
NZ	2015	Mexicali 125 Ormiston Rd Unit 22 Botany Junction Flatbush Auckland	1 x HCVFO Series Hood 3100x1350x550mm
NZ	2015	Burger Fuel Tenancy 09 102 Pakuranga Rd Auckland 2010	1 x HCPFO Series Hood 2400x1600x800mm 1 x HCFO Series Hood 3150x1600x800mm
NZ	2015	Pita Pit Lambton, Wellington	1 x HCO Series Hood 1900x1200x800mm
NZ	2015	Park Road Miramar Wellington	1 x HCPF Series Hood 1800x1600x800mm 1 x HC(F)E Series Hood 3700x1350x800mm
NZ	2014	Pita Pit 151 Lincoln Rd Henderson, Auckland	1 x HCO Series Hood 1800x1200x800mm
NZ	2014	Origami Japanese Restaurant 158 Cuba Street, Te Aro, Wellington City	1 x HCF Series Hood 4900x1600x800mm
NZ	2014	Curry Pot South Indian Restaurant 88 Riddiford St Newtown Wellington 6021	1 x HCFO Series Hood 3000x1350x800mm
NZ	2014	Nomad restaurant Auckland	1 x HCVE Series Hood 3350x1350x550mm
NZ	2014	OKO desert restaurant Skycity metro centre Auckland	1 x HCES Series Hood 2150x1200x800mm
NZ	2014	Coffee Club Auckland metro centre	1 x HCE Series Hood 3100x1200x800mm
NZ	2014	Hot Chilly PO Box 2089 Wellington 6035	1 x HCE Series Hood 1500x1200x800mm 1 x HCE Series Hood 2200x1200x800mm
NZ	2013	Chilando Mexican Taqueria McAlpine Husmann	1 HCF Series Hood 2400x1200x800mm
NZ	2013	Charley Noble Eatery and Bar Ground Floor, Huddart Parker Building, No 1 Post Office Square, PO Box 9689, Wellington	1 HCFO Series Hood 4550x1350x800mm 1 HCFO Series Hood 4700x1350x800mm
NZ	2013	Casino Bar and Kitchen Christchurch	1 V-Bank Series Hood 5000x1200x450mm 1 V-Bank Series Hood 5000x1400x450mm

AOM AUSTRALIA

22/54 BEACH ST KOGARAH NSW 2217 Tel 1300 903 788 Fax 1300 904 088

www.aomaus.com.au

Email: info@aomaus.com.au

Note to AOM Series Hood codification:

- HCES: Exhaust hood, with or without air supply plenum
- HCOS: Exhaust hood with ozone generator, with or without air supply plenum
- HCFS: Exhaust hood with electrostatic filter, with or without air supply plenum
- HCFOS: Exhaust hood with electrostatic filters & ozone generator, with or without air supply plenum
- HCFDS: Exhaust hood with electrostatic filters (double pass), with or without air supply plenum
- HCFIS: Island exhaust hood with electrostatic filters, with or without air supply plenum
- HCD: Dishwasher hood

AOM AUSTRALIA

22/54 BEACH ST KOGARAH NSW 2217 Tel 1300 903 788 Fax 1300 904 088

www.aomaus.com.au

Email: info@aomaus.com.au